

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.


Dated: 16-06-2025

It is certified that an inspection team headed by Dr. Pawan Kumar Keshyap
(Name of Officers with designation) from Public Health Department, PHED

inspected the Om Memorial Public School Baghaura, Rajgarh, MZP (Name &
Address of the school) on 16.06.2025 (date of inspection) and on the basis of Water
Test Report (Attached) bearing no. dated. of

..... (PHED Lab) certified that the
Om Memorial Public School Baghaura, Rajgarh, MZP (Name of school) has safe drinking water facilities
for the students and members of staff of the institution. School is also maintains the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till One year....

Signature with Seal: 
Name Dr. Pawan Kumar Keshyap
Designation M. Superintendent
Name & Address of the Office / Department.

To the Principal

Om Memorial Public School Baghaura,
(Name & Address of the Institution) Rajgarh, MZP.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Jal Jeevan Mission

Har Ghar Jal



District Level Water Analysis Laboratory , Uttar Pradesh Jal Nigam (Rular),Mirzapur.

STP Campus, Pakka Pokhra, Mirzapur, Uttar Pradesh, 231001 (Test Address only)

Test report

Sample ID:

U1972642S16855224

User Information

Name:

OM MEMORIAL PUBLIC SCHOOL

Mobile:

9569373427

Email:

ommemorialpublicschool@gmail.com

Pin
Code:

231001

Full
Address:

BAGHAURA RAJGARH MIRZAPUR, UP 231001

Sample description

Source
of
Sample:

Schools

Village:

BAGHAURA

Gram
Panchayat:

BAGHAURA

Block:

RAJGARH

District:

Mirzapur

State:

Uttar Pradesh

Address:
Latitude:

Remarks:
Longitude:

OM MEMORIAL PUBLIC SCHOOL

Date & time of sample collection

13.06.2025 | 03:09:00 PM

Date & time of sample received in lab

13.06.2025 | 04:24:00 PM

Date & time of sample analysed

13.06.2025 | 04:51:00 PM

Date & time of report generation

14.06.2025 | 12:39:53 PM

Test results

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Chloride (as Cl)*	mg/l	250	1000	16.000	
2	Colour*	Hazen units	5	15	5.000	
3	Fluoride (as F)*	mg/l	1	1.5	0.230	
4	Free residual Chlorine	mg/l	0.2	1	0.000	

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
5	Iron (As Fe)*	mg/l	1	No Relaxation	0.260	
6	Nitrate (as NO3)*	mg/l	45	No Relaxation	8.640	
7	Odour*	NA	Agreeable	Agreeable	0.000	
8	pH*	NA	6.5–8.5	No Relaxation	7.130	
9	Sulphate (as SO4)*	mg/l	200	400	15.760	
10	Taste*	NA	Agreeable	Agreeable	0.000	
11	TDS*	mg/l	500	2000	296.000	
12	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	264.000	
13	Total Arsenic (As As)*	mg/l	0.01	No Relaxation	0.000	
14	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
15	Total Hardness (As CaCO3)*	mg/l	200	600	228.000	
16	Turbidity*	NTU	1	5	2.180	

Note:

- 1)*indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Authorised signatory

Ashok Kumar Yadav (Test Lab Incharge)

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC. Copyright ©copy NJJM 2025

Print